

25 February 2016

**Wilmaplex Pty Ltd.
57 Lathams Road,
Carrum Downs, Vic 3201
Mr Graham storey**

RE/ Wilmaplex Sub Floor Vent Anti Spark Hole (punched)

This is to confirm that Wilmaplex Sub Floor Vent Anti Spark Hole (punched), code SFV HAS of sizes 230 x 160, 230 x 76 and 190 x 190mm, see Figure 1, were fabricated from corrosion-resistance steel and with perforations of less than 2mm in diameter, after inspection the vents were found to comply with the provisions of AS 3959, “Construction of buildings in bushfire prone Areas”, and the Building Code of Australia requirements.

The sub-floor ventilation shall be design in a manner that complies with Section 3.4.1 of the Building Code of Australia.



Figure 1 Sub-floor Vent anti Spark Hole.

*Dr Con Adam (Director)
CEMQA Pty. Ltd.
P.O. Box 2660
Mt. Waverley, VIC 3149*